



FIRE SAFETY CERTIFICATE

APPENDIX - XII

No. ज.ह.जा.ग.म./अग्नि/2025/कार्ड-45

Dated: 20/06/2025

Certified that the Rishi Vidya Educational School (name of the building or premises) at Rajgad (address) comprised of Four basement(s) and Four (upper floors) owned/ occupied by Rishi Vidya Educational Foundation (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 31.05.2025 (date of inspection) in the presence of Madhav Panpatte (name and addresses of the Manager/ Secretary or his representative) and that the building/ premises is fit for occupancy upto classes 1 to 10 (X/ XII) With effect from 2025-26 for a period of one year in accordance with rule and subject to compliance of specific conditions as appended:-

- 1.
- 2.
- 3.
- 4.

Issued on 20/06/2025 (date of issue) at Jalna (place) by

*Strike out whichever is not applicable.

Signature with Seal: [Signature]

Name : (MADHAV PANPATTE)

Designation : Chief Fire Officer

Name & Address of Department/ Office : Jalna City Municipal Corporation Jalna

To

Rishi Vidya Educational School
Rajgad, Mantha Road, At. Post. Kharpudi,
(Name & Address of the Institution) Tq. Dist. Jalna

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled an annulled due to
(reasons to be recorded).

(Name and designation of the authorized signatory)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



जालना शहर महानगरपालिका, जालना

अग्निशमन विभाग

प्रशासकीय इमारत, रेल्वेस्टेशन रोड, जुना जालना-431203



Email ID- comcjalna@gmail.com https://mcjalna.in

Website - jalnamahaulb.maharashtra.gov.

Tel. No. 02482-230101, 233101.

जा/क्र.जाशम/FNOC/ 2025/- 28

Date:- 18/06/2025

"This certificate Must Be Renewed Every Year"

To,

Mr. Hema Maheshwar Sontakke (Principal),
For Rishi Vidya Educational School,
At. Kharpudi, Gut No.33, Mantha Road
Tq. & Dist. Jalna.

Subject:- Grant of "Final No-Objection Certificate" for your Rishi Vidya Educational School of Building on At. Kharpudi, Gut No.33, Mantha Road, Tq. & Dist. Jalna.

- Reference:-**
1. This Office Last Year "Provisional Fire NOC" Certificate No. जा/क्र.जाशम/FNOC/2024/22 Date. 03.07.2024.
 2. Applicant Online FNOC/Application No.:- 2429151407039XBWJJ2EFF Date- 18.10.2024
 3. Certificate Submitted by License Agency M/S FSI Corporation Services, License No. MFS/LA/RF-385/RD-363/RP-95 Letter:- "Form A" (FSI/2025/056) Date. 02.04.2025
 4. Fire Officer Inspection Report. Date.31/05/2025.

This has reference to the above This office has No Objection for "Final Fire Approval" for following proposed construction of Rishi Vidya Educational School, Occupancy.

This is a Proposal for construction of Rishi Vidya Educational School, building as detailed given below.

Sr. No	Particular	Height Mtr.	Building	Floor	Area Sq.Mtr	Build up Area Sq.Mtr	Fire Fund	NOC Fees
1.	Rishi Vidya Educational School	9.60	4	Gr. + 1	8000.00 (Total Plot Area)	6311.709	650108/-	5000/-
Total Payable Amount Rs.- (Five Thousand Rupees Only)							5000/-	

Total Plot area is 8000.00 Sq. Mtrs. and Proposed built up area is 6311.709Sq. Mtrs. (incl. area free of FSI).

As per Section 25-Appendix-Part III of the Maharashtra Fire Prevention and Life Safety Measures Act, 2006, Rules 2009 and amended 2023. Fire Capitation Fees Payable Amount Rs. 6,50,108/- (Rs. Six Lac Fifty Thousand One Hundred Eight Rupees Only) And "Provisional Fire NOC" Fees Rs.5000/- (Rs. Five Thousand only Rupees Only) Total Payable Amount 6,55,108/-(Rs. Six Lac Fifty Five Thousand One Hundred Eight Rupees Only) Paid By Cheque No. "000397" Bank Name HDFC Bank, Branch – Jalna, IFSC Code- HDFC0009256 Date. 03.07.2024

And "Final Fire NOC" Fees Payable Amount Rs.5000/- (Rs. Five Thousand only) paid By Cheque No. "648975" Bank Name IDBI Bank, Branch – Jalna Date.13/06/2025. (JMC Book No./ Receipt No. 597/15). Date. 13/06/2025.

Since the Fire Fighting arrangements provided is installed by License Agency i.e. M/s FSI Corporation. Bearing License No. MFS/LA/RF-385/RD-363/RP-95 "Form-A" Ref. No. (FSI/2025/056) issued by Directorate of Maharashtra Fire Service and has submitted Certificate in "Form- A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009 & Revised 2023 this office is issuing a "Final No-Objection Certificate" for your following building having built up area admeasuring to 6311.709Sq.Mtrs.

The detail of the proposed Construction is as under,

Sr. No.	Floor	Build up Area in Sq. Mtrs.
01	Main Building 1 Ground Floor + First Floor	1810.12 Sq. Mtrs
02	Main Building 2 Ground Floor + First Floor	716.599 Sq. Mtrs
03	Main Building 3 Ground Floor + First Floor	1201.42 Sq. Mtrs
04	Main Building 4 Ground Floor + First Floor	2583.57 Sq. Mtrs
Total Build Up Area in Sq. Mtrs.		6311.709 Sq. Mtrs

The open aces around the building are as follows:

Direction	Building line to plot boundary in Mtrs.
West	Other Owner Property
North	Devmurti – Kharpudi Shiv
East	Other Owner Property
South	Gut No. 33

As per Fire ACT 2006 Under Section 3(1) Minimum requirement for fire fighting installation. All Installation by (Maharashtra fire service) Govt. authorized license holder agency. The Following fire protection system shall be provided.

Sr. No	Fire Fighting Installation	Requirement as per NBC 2016 & Fire Act 2006/Revised Act 2023.	Remarks
1.	Open Space all around the building shall be provided for the movement of Fire Tender and which will carry 25 tons. Weight capacity.		
2.	Portable Fire Extinguisher.	Required at each floor.	Shall be conforming to IS:15683 & placed at strategic location & NBC-2016 IV Clause 5.1 should be accordance with accepted standard 4(17). A. ABC Type Extinguisher. B. CO2 Type Extinguisher.
3.	Hose Reel	Required at each floor.	On each floor in the staircases landing for fire fighting. The first aid hose reel shall be connected directly to hydrant line and diameter of the hose reel shall not be less than 19mm confirming to IS:884:1985 & NBC-2016 Part IV clause 5.1.1(b), 4(18), 4(17)
4.	Hose Box.	Required at each floor.	With Front side glass With Key Lock/Unlock System containing hose pipe of 30 mtrs length & Branch pipe shall be provided.
5.	Automatic Sprinkler System.	Required at Auditorium Hall	As per the plan sprinkler system is proposed only in common passage sprinkler system shall be installed in entire building in addition to common passage and lobby confirming to IS:11042016 & shall be as per NBC-2016 Part IV clause 5.1.3 and drawing of the same shall be submitted while obtaining Final No objection certificate.

6.	Wet Riser/Down Comer	Required at each Floor.	100/150 mm MS Pipe "C" type in vertical position connected to water source through pump with hydrant outlet on each floor (0.9 mtrs. above landing) Required to provide near main Staircase, Landing of Valve should be installed confirming to IS:5290 & NBC part IV clause 5.1 & accepted standard 4(19)
7.	Yard Hydrant the building.	Not Required.	Hydrant Point should be provided with 30 mtrs. of delivery hose with coupling confirming to IS:14933-2001 along with standard branch(Universal)confirming to IS-2871.
8.	Auto DG Backup	Required	Required for all fire safety systems as per NBC-2016 Part IV-clause No.3.4.6.2
9.	Manually Operated Electronic Fire Alarm System.	Required at Lobby	Manually operated Fire alarm should be provided; it should be connected to alternate power supply in case of emergency.
10.	Automatic Detection and Alarm System (Fire Alarm Panel).	Required at Auditorium Hall	Smoke/Heat Detector should be provided; it should be connected to alternate power supply in case of emergency & shall be confirming as per NBC Part IV clause 4.9
11.	Underground Static water Storage tank combined capacity for wet-Riser, Yard Hydrant and Sprinkler per set of pumps.	Not Required.	This water storage should be used exclusively for Fire Fighting purpose. Shall be confirming as per NBC-2016 clause 5.1.2.1
12.	Terrace Tank over Respective Tower Terrace.	Required 10,000 Ltr	This water storage should be used exclusively for fire fighting purpose
13.	Pump Near Underground Static Water Storage Tank (Fire Pump)with minimum pressure of 3.5 kg/cm ² at Remotest location	Not Required.	Fire Fighting pump shall be well maintained & shall be confirming to NBC-2016 Part IV clause 5.1.2.2

14.	Pump near the terrace tank level with minimum Pressure of 3.5 kg/cm ² Booster Pump.	01 Nos. Booster Pump 3.5 Kg/cm ²	Fire Fighting pump shall be well maintained & shall be confirming to NBC-2016 Part IV clause 5.1.2.2
15.	Fire Brigade connection (Fire Vehicle Inlet) for Static water tank and for Hydrant System.	Required at Main Gate	As be easily visible and accessible
16.	Auto Glow Emergency Exit Board, Fire Brigade Contact Number Board, No Smoking, Extinguisher Type and it's Numbering Board.	Required in Staircase and Lobby.	as per the guidelines given in IS:9457 for safety colour and safety IS:12349 for fire protection safety signs IS:12407 for Graphics symbols for Fire Protection Plan.
17.	Fire Alert Hot line security system	Required at security control room.	For directly connecting the Fire Fighting system of the building to Fire Deptt. Control room.
18.	Fire Resistance Door.	Required at each floor.	Near fire escape staircase Fire doors shall be constructed of suitable non-combustible materials NFPA 80 requires that fire doors be made of materials that are able to withstand the temperatures and pressures of a fire. This includes materials such as steel, wood, and aluminum. and two fire doors may be fitted in one opening if each door is capable of closing the opening by itself and the two doors together achieve the required level of fire resistance.
19.	Fire Bucket Stand	Required Near Transformer	Red Colour MS Square tube and 3Ft x 2Ft Galvenised sheet 4No.s/ Stand.
20.	Lift (Elevator)	Not Required	Lifts shall be constructed as per National Building Code Section 5 Annex 1.5.

Statutory Provisions Under Maharashtra Fire Prevention and Life Safety Measures Act, 2006, Rule 2009 & Revised 2023.

1. Under Section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" (here in after referred to as "said Act"). The applicant (developer, owner, occupier by whatever name called) shall comply with all the Fire and Life Safety measures adhering to National Building Code of India, 2005 and as amended from time to time failing which it shall be treated as a violation of the said Act.
2. It is presumed that you have completed the work adhering to the provisions under Section-3 of the said Act.
3. Under sub-section (3) of Section 3, it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance office prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).
4. Under sub section(4) of Section3, no person shall tamper with, alter, remove or cause any injury or damage to any fire prevention and life safety equipment installed in any such building or part there of or instigate any other person to do so.

Following is the list and detailed details of equipment mentioned in "Form A" provided by your licensing agency.

Sr. No	Equipment	Quantity
1.	Main Electrical Pump 7.5 HP	01 Nos.
2.	Main Electrical Fire Pump Auto/Manual Pump	01 Nos.
3.	63 MM Single Headed Hydrant Valve	05 Nos.
4.	RRL 63 MM Long 15 MTR Hose Pipe	05 Nos.
5.	SS Simple Branch	05 Nos.
6.	Hose Reel Hose 30 Mtr. With Shut Off Nozzle	04 Nos.
7.	Single Door Hose Box	05 Nos.
8.	Fire Alarm Panel 4 Zone	01 Nos.
9.	Hooter (Agni Make)	03Nos.
10.	MCP	03 Nos.
11.	Smock Detector (Agni Make)	20 Nos.

We further certify under the Maharashtra Fire Prevention and Life Safety Measures Act, 2006, Rules 2009 and amended 2023 that the said buildings of the establishment are kept in good repair and workable condition. In this regard 06 months maintenance and inspection certificate in Form B from your licensed agency should be submitted to our office. And along with this, it will be mandatory to renew fire protection certificate every year.

Fire extinguishers shall be well maintained and in excellent working condition at all times in accordance with the Provisional No-Failure Certificate. If the fire protection system is not maintained, trimmed, this "NOC." Please note that cancellation will be done without any notice and you will be solely responsible for any loss of life or property.

The condition mentioned in "Provisional Non-Enforcement Certificate" and "Final Non-Enforcement Certificate" shall remain unchanged. The undersigned reserves the right to modify any additional recommendations as may be deemed appropriate during stage wise inspection due to statutory provisions as amended from time to time and in the interest of the protection of the hospital. In case of transfer of activity or plot or any future expansion, a No-Transfer Certificate (NOC) is required from this office.

As per Fire ACT 2006 Under Section 3(1), NBC 2016, Fire ACT 2006 & Fire revised Act 2023. This "**Final No-Objection Certificate**" is mere recommendation letter and is valid subject to fulfilment of the above conditions.

Note:- This is your "**Final No-Objection Certificate**" and you need to obtain "**Renewal No-Objection Certificate**" of this certificate every year otherwise your final certificate will not be valid. Also please note that you will be charged late charges as per the Maharashtra Fire Prevention and Life Saving Measures Act, 2006 (No.3 of 2007) amended 2023.



(MADHAV PANPATTE)
CHIEF FIRE OFFICER,
JALNA MUNICIPAL CORPORATION,
JALNA.